

島根原子力発電所 沿岸定点の水温 (平成29年4月)

観測時刻 10 時

場所	日 水深	観測時刻 10 時																			月間													
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	水深別 平均	最高 最低	
1号機放水口	1m	13.7	13.6	13.7	13.8	14.1	14.0	14.2	14.3	14.3	14.2	14.2	14.2	14.3	14.5	14.7	14.8	14.9	15.0	15.4	15.3	15.3	15.6	15.4	15.1	15.2	15.5	15.7	15.7	16.0	16.1	14.8	16.1	13.6
	2m	14.0	13.9	13.9	14.1	14.4	15.2	14.8	15.0	15.0	14.6	15.1	15.1	15.1	15.2	15.5	15.4	*	15.9	16.3	16.1	16.2	16.2	15.7	15.7	15.9	17.0	16.4	16.7	16.6	16.6	15.4	17.0	13.9
	4m	14.1	14.1	14.1	14.2	14.5	14.6	14.7	14.7	14.7	14.7	14.9	14.9	14.9	15.1	15.3	15.6	15.8	15.6	16.0	15.9	16.1	16.2	16.2	15.9	16.0	16.2	16.3	16.5	16.7	16.9	15.4	16.9	14.1
輪谷湾	1m	13.7	13.6	13.7	13.8	14.3	14.4	14.3	14.5	14.7	14.3	14.2	14.4	14.4	14.5	14.7	15.0	15.0	15.4	15.4	15.5	15.5	15.7	15.6	15.3	15.4	15.9	15.9	16.0	16.0	16.1	14.9	16.1	13.6
	3m	13.7	13.5	13.7	13.8	14.1	14.1	14.2	14.4	14.3	14.3	14.3	14.1	14.3	14.4	14.7	14.9	14.9	15.0	15.4	15.3	15.4	15.6	15.5	15.3	15.2	15.6	15.9	15.8	16.0	16.0	14.8	16.1	13.5
片匂	1m	13.4	13.4	13.6	13.7	14.4	14.3	14.2	14.7	14.6	14.0	14.1	13.9	14.2	14.2	14.7	14.9	15.0	15.1	15.0	15.2	15.3	15.5	15.6	15.4	15.4	16.1	15.9	16.0	15.9	15.9	14.8	16.1	13.4
	3m	13.6	13.5	13.6	13.8	14.4	14.3	14.3	14.5	14.7	14.1	14.2	14.0	14.2	14.3	14.7	14.9	15.0	15.1	15.1	15.3	15.4	15.5	15.6	15.4	15.4	16.0	16.0	16.0	15.9	15.9	14.8	16.1	13.4
御津	1m	13.8	13.9	13.9	14.2	14.8	14.6	14.5	14.8	15.1	14.6	14.5	14.3	14.5	14.8	15.1	15.5	15.8	15.3	15.4	15.6	15.8	16.2	16.1	15.9	16.0	16.4	16.3	16.5	16.8	16.6	15.3	16.8	13.8
	3m	13.9	13.9	13.9	14.2	14.8	14.7	14.6	14.9	15.1	14.7	14.6	14.4	14.5	14.8	15.1	15.4	15.8	15.4	15.5	15.7	15.8	16.2	16.2	15.8	15.7	16.4	16.2	16.5	16.6	16.6	15.3	16.6	13.9

※1 作業による欠測

場所	日 水深	水深別平均					月間	
		上旬 (3日)	中旬 (11日)	下旬 (21日)	水深別 平均	最高	最低	
※2 放水口沖 (1号)	0m	13.8	14.3	15.5	14.5	15.5	13.8	
	1m	13.8	14.3	15.5	14.5	15.5	13.8	
	2m	13.8	14.3	15.5	14.5	15.5	13.8	
	3m	13.8	14.3	15.4	14.5	15.4	13.8	
	4m	13.8	14.3	15.4	14.5	15.4	13.8	
	5m	13.8	14.3	15.4	14.5	15.4	13.8	
	6m	13.8	14.3	15.4	14.5	15.4	13.8	
	7m	13.8	14.3	15.4	14.5	15.4	13.8	
	8m	13.8	14.3	15.4	14.5	15.4	13.8	
	9m	13.8	14.3	15.4	14.5	15.4	13.8	
10m	13.8	14.3	15.4	14.5	15.4	13.8		

※2 放水口沖水温は、可搬式水温計による実測値。